

Certificate of Constancy of Performance

Intertek

0359-CPR-00633

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Product(s): Photoelectric Smoke Alarm with Z-Wave Wireless Interconnect and Heat Detection
(refer to attached appendix for details and conditions)

placed on the market under the name or trade mark of: Siterwell Electronics Co., Limited
No.666 Qingfeng Road, Jiangbei District, Ningbo, Zhejiang Province, China

and produced in the manufacturing plant(s): Siterwell Electronics Co., Limited (SITERWCN.01)
No.666 Qingfeng Road, Jiangbei District, Ningbo, Zhejiang Province, China

Intended use: Fire Safety

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN14604:2005+AC:2008

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **08-Dec-2017** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Notified Body
0359

Intertek Testing & Certification Limited
Cleeve Road, Leatherhead
Surrey, KT22 7SB
Tel: + 44 (0)1372 370900
Fax: +44 (0)1372 370977
E-mail: cpd.uk@intertek.com

Nick Jones
Certification Officer



Date 26-Apr-2018
Issue 2

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ, United Kingdom

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Certificate of Constancy of Performance



0359-CPR-00633

Appendix to Certificate of Constancy of Performance 0359-CPR-00633

The details and conditions of use for the Photoelectric Smoke Alarm with Z-Wave Wireless Interconnect and Heat Detection, placed on the market under the name or trade mark of:

Siterwell Electronics Co., Limited

No.666 Qingfeng Road, Jiangbei District, Ningbo, Zhejiang Province, China

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Products compliant with EN14604:2005+AC:2008:

Model	Manufacturing Location	Description
GS559B	SITERWCN.01	Photoelectric Smoke Alarm with Z-Wave Wireless Interconnect (868.4 MHz) and Heat Detection

Batteries:

2 x 1.5 V Alkaline AA batteries, as listed below:

Manufacturer	Model No.
Energizer	E91
Gold Peak Group	GP15A
Zhejiang Mustang Battery Co., Ltd	Raymax LR6

Conditions of use:

Suitable for indoor applications only

General notes:

1. Evaluated under Intertek project number 102887297 and 102956305.
2. The GS559B Photoelectric Smoke Alarm has not been approved for installation into leisure accommodation vehicles (LAVs).
3. Radio frequency and heat detection capabilities of smoke alarms are outside the scope of EN14604:2005+AC:2008; the wireless interconnect (radio-link) and heat detection functions of the GS559B Photoelectric Smoke Alarm, are therefore not covered by this approval.
4. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.

Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SB
Tel: + 44 (0)1372 370900, Fax: +44 (0)1372 370977, E-mail: cpd.uk@intertek.com

0359-CPR-00633
Issue 2

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ, United Kingdom

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.